



BUSSELTON WATER

Busselton Water

Report to the Department of Health

for the period

1 July to 30 September 2025

Busselton Water
PO Box 57
Busselton WA 6280
P: (08) 9781 0500
F: (08) 9754 1075
www.busseltonwater.wa.gov.au

Submitted to:
The Advisory Committee for the Purity of Water
Busselton Water's Website
CEO, Busselton Water (David Hughes-Owen)

Table of Contents

1.0	WATER PROVIDER INFORMATION	2
1.1	System Information	2
2.0	PERFORMANCE SUMMARY	3
2.1	Treated Water – Microbiological Water Quality	3
2.2	Distributed Water - Microbiological Water Quality	4
3.0	MICROBIAL PERFORMANCE	5
3.1	Microbiological - Exception Notifications	5
3.2	Microbiological - Incident Specific Information	5
4.0	CHEMICAL – HEALTH RELATED PERFORMANCE	6
4.1	Chemical – Health Related – Exception Notifications	6
4.2	Chemical – Health Related	6
5.0	PHYSICAL AND CHEMICAL – AESTHETIC PERFORMANCE	9
5.1	Physical and Chemical - Aesthetic	9
6.0	PERFLUOROALKYL AND POLYFLUOROALKYL SUBSTANCES (PFAS) PERFORMANCE	11
6.1	Perfluoroalkyl and Polyfluoroalkyl Substances (PFAS)	11
7.0	RADIOLOGICAL PERFORMANCE	14
7.1	Radiological – Exception Notifications	14
7.2	Radiological Performance	14
8.0	PLANNED SAMPLE SUMMARY (QUARTER ENDING 30 SEPTEMBER 2025)	16
8.1	Planned Sample Exceptions	16
9.0	GENERAL NOTES / OTHER NEWS	16

1.0 Water Provider Information

Water Provider Contact Details	
Name of Company	Busselton Water
Company Address	1 Fairbairn Road, Busselton WA 6280
Company Phone	08 9781 0500
Company Email	admin@busseltonwater.wa.gov.au
Chief Executive Officer	David Hughes-Owen
DoH Liaison Officer	Dr Stacey Hamilton, General Manager Operations and Planning

1.1 System Information

Busselton Water operates one large, interconnected water supply system with five bore sites consisting of eight active production bores, supplying three water treatment plants. Busselton Water operates its distribution system as one locality ("Busselton") and has strategically placed sampling points throughout the distribution network.

Busselton Water's water supply is sourced from bores constructed in the Leederville and Yarragadee aquifers. The raw groundwater has turbidity and total iron concentrations above the drinking water guideline limits, but these are readily removed by oxidation, aeration and filtration, and then disinfected at Busselton Water's treatment plants before distribution into the reticulation network. Significant focus and planning for growth is being applied to the establishment of an inland borefield that avoids the impacts of saltwater intrusion.

Busselton Water supplies drinking water to more than 30,000 people within the Busselton townsite and close environs such as Port Geographe, Siesta Park, Vasse and Wonnerup. Water is also supplied to the Water Corporation under a Water Supply Agreement to augment their Dunsborough supply. As a sought-after tourist destination, this figure can rise significantly during weekends and holiday periods. The average daily system demand for the reporting period was 12.0 ML/day (extracted).

2.0 Performance Summary

2.1 Treated Water – Microbiological Water Quality

Microbiological water quality analyses for treated water samples are collected downstream of the chlorinators at the water treatment plants. Compliance limits are summarised in the following table.

Samples were analysed for thermotolerant coliforms, *E. coli* and Thermophilic *Naegleria* during the period. No microbial activity in relation to these parameters was detected during the period at any of the sample locations. Busselton Water remains fully compliant with the Australian Drinking Water Guidelines (ADWG) and the Memorandum of Understanding with the Department of Health in respect to *E. coli* and *N. fowleri* ¹.

Period	<i>Escherichia coli</i> (<i>E. coli</i>)				Thermophilic <i>Naegleria</i>			<i>Naegleria Fowleri</i> ¹		
	No. of Samples	No. of Non-conforming Samples	Maximum Individual Value	Rolling 12 Months Compliance	No. of Samples	Detected	Rolling 12 Months Compliance	No. of Samples	Detected	Rolling 12 Months Compliance
Jul-25	17	0	<1	100%	17	0	100%	0	-	100%
Aug-25	22	0	<1	100%	22	0	100%	0	-	100%
Sep-25	27	0	<1	100%	27	0	100%	0	-	100%
Total for Third Quarter 2025	66	0	-	-	66	0	-	0	-	-
Third Quarter 2025 Performance	100%			-	100%		-	100%		-
Required Compliance:	100%				95%			100%		

Note 1: Tests for *Naegleria Fowleri* only required if Thermophilic *Naegleria* is detected.

2.2 Distributed Water - Microbiological Water Quality

Microbiological water quality analyses for nine locations within the distribution network are sampled weekly and are summarised in the following table.

Samples were analysed for thermotolerant coliforms, *E. coli* and Thermophilic *Naegleria* during the period. No microbial activity in relation to these parameters was detected during the three months at any of the sample locations. Busselton Water remains fully compliant with the Australian Drinking Water Guidelines (ADWG) and the Memorandum of Understanding with the Department of Health in respect to *E. coli* and *N. fowleri*¹.

Period	<i>Escherichia coli</i> (<i>E. coli</i>)				Thermophilic <i>Naegleria</i>			<i>Naegleria Fowleri</i> ¹		
	No. of Samples	No. of Non-conforming Samples	Maximum Individual Value	Rolling 12 Months Compliance	No. of Samples	Detected	Rolling 12 Months Compliance	No. of Samples	Detected	Rolling 12 Months Compliance
Jul-25	36	0	<1	100%	36	0	100%	0	-	100%
Aug-25	36	0	<1	100%	36	0	100%	0	-	100%
Sep-25	45	0	<1	100%	45	0	100%	0	-	100%
Total for Third Quarter 2025	117	0	-	-	117	0	-	0	-	-
Third Quarter 2025 Performance	100%			-	100%		-	100%		-
Required Compliance:	100%				95%			100%		

Note 1: Tests for *Naegleria Fowleri* only required if Thermophilic *Naegleria* is detected.

Note 2: Sampling for *E. coli* in the distribution network commenced on 30 March 2010. There has not been an *E. coli* detection in the distribution network to date.

Note 3: The last known Thermophilic *Naegleria* detection in the distribution network was at Vernon Track on 16 August 2011.

3.0 Microbial Performance

3.1 Microbiological - Exception Notifications

Microbiological Water Quality Exceptions								
Locality	Population Served	Date	Microbiological Characteristic	MoU Alert Level	Remedial Action	DoH Notified	Close Out Date	
Busselton	>30,000	01/07/2025 to 30/09/2025	Nil					

3.2 Microbiological - Incident Specific Information

Microbiological Incidents				
Locality	Date of Incident	Details of Incident	MoU Alert Level	Remedial Action
Busselton			Nil	

4.0 Chemical – Health Related Performance

The results of water samples collected from the operating production bores (raw water) and at the assessable distribution sampling points (distribution water) during the period are summarised in Table 4.2 for health-related guidelines. They show that the water supply is fully compliant with the health-related Australian Drinking Water Guidelines, the operating licence issued by the ERA and the protocols of Busselton Water’s Memorandum of Understanding with the Department of Health.

4.1 Chemical – Health Related – Exception Notifications

Health-Related Chemical Water Quality Exceptions							
Locality	Population served	Date	Health Related Chemical Characteristic	MoU Alert Level	Remedial Action	DoH Notified	Close Out Date
Busselton	>30,000	01/07/2025 to 30/09/2025			NIL		

4.2 Chemical – Health Related

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Antimony	mg/L	0.003	0.001	NR			9	9	ND	100%
Arsenic	mg/L	0.01	0.001	NR			9	9	ND	100%
Barium	mg/L	2.0	0.01	NR			9	9	0.3	100%
Beryllium	mg/L	0.06	0.001	NR			9	9	ND	100%

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Bismuth (Filtered)	mg/L	10	0.005	27	27	ND	27	27	ND	100%
Bismuth (Total)	mg/L	10	0.005	27	27	ND	27	27	ND	100%
Boron	mg/L	4.0	0.05	NR			9	9	0.19	100%
Bromodichloromethane	mg/L	0.25*	0.005	NR			3	3	ND	100%
Bromoform	mg/L	0.25*	0.005	NR			3	3	0.0021	100%
Cadmium	mg/L	0.002	0.0005	NR			9	9	ND	100%
Chlorine (Total)	mg/L	5		NR			117	117	0.88	100%
Chloroform	mg/L	0.25*	0.0005	NR			3	3	ND	100%
Chromium (VI)	mg/L	0.05	0.002	NR			9	9	ND	100%
Copper	mg/L	2	0.001	NR			9	9	0.022	100%
Dibromochloromethane	mg/L	0.25*	0.001	NR			3	3	ND	100%
Fluoride	mg/L	1.5	0.1	27	27	0.9	27	27	0.5	100%
Lead	mg/L	0.01	0.001	NR			9	9	ND	100%
Manganese (Soluble)	mg/L	0.5	0.005	27	27	0.076	27	27	ND	100%
Manganese (Total)	mg/L	0.5	0.005	27	27	0.077	27	27	0.015	100%
Mercury	mg/L	0.001	0.0001	NR			9	9	ND	100%
Molybdenum	mg/L	0.05	0.001	NR			9	9	ND	100%
Nickel	mg/L	0.02	0.001	NR			9	9	ND	100%
Nitrate-N	mg/L	50	0.01	8	8	ND	9	9	0.02	100%
Nitrite N	mg/L	3	0.01	8	8	0.02	9	9	ND	100%
Selenium	mg/L	0.01	0.001	NR			9	9	ND	100%
Silver	mg/L	0.1	0.001	NR			9	9	ND	100%

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Total Trihalomethanes	mg/L	0.25*	0.001	NR			3	3	0.0029	100%
Uranium	mg/L	0.02	0.001	NR			9	9	ND	100%

- Note 1:** Raw water is blended and treated prior to supply to consumers. Raw water is not provided to consumers and raw water data presented in this report is for operational purposes.
- Note 2:** Chlorine Total is a Busselton Water in-house test. All others are NATA accredited test results. The operating target for residual chlorine in the reticulation system is 0.4 – 0.6 mg/L. Total chlorine levels will be higher than residual levels.
- Note 3:** The average Chlorine Total level in the distribution network for the reporting period was 0.56 mg/L.
- Note 4:** The maximum Chlorine Total level of 0.88 mg/L in the distribution network for the reporting period was recorded at Thomas Street on 31 July 2025. No adverse customer or operational impacts resulted. The aesthetic guideline value of 0.6 mg/L is exceeded on some occasions to ensure the microbiological safety of our water supply.
- Note 5:** Busselton Water does not add fluoride to the water. The naturally occurring fluoride levels vary from bore to bore. Fluoride levels in the drinking water vary with location and time and historically have fallen anywhere between 0.1 mg/L and 1.0 mg/L. The 12 month (Oct-24 to Sep-25) average Fluoride level in the distribution network was 0.43 mg/L.
- Note 6:** * The concentration of trihalomethanes, either individually or in total, in drinking water should not exceed 0.25 mg/L.

ADWG	Australian Drinking Water Guidelines
Bq/L	Becquerels per litre
CFU	colony forming units
HU	Hazen Units
mg/L	milligrams per litre
NA	Not Applicable
ND	Not Detected
NR	Not Required
NTU	Nephelometric Turbidity Units
pH	Acidity/basicity
uS/cm	Micro siemens per centimetre

5.0 Physical and Chemical – Aesthetic Performance

The results of water samples collected from the operating production bores (i.e., raw water) and at the assessable distribution sampling points (i.e., distribution water) during the period are summarised in Table 5.1 for aesthetic related guidelines. The treatment process reduces colour and iron content to below those levels specified in the Australian Drinking Water Guidelines (ADWG).

5.1 Physical and Chemical - Aesthetic

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Alkalinity (Bicarbonate)	mg CaCO ₃ /L	No Guideline	5	8	No Guideline	180	9	No Guideline	160	No Guideline
Alkalinity (Carbonate)	mg CaCO ₃ /L	No Guideline	5	8	No Guideline	9.7	9	No Guideline	ND	No Guideline
Alkalinity (Hydroxide)	mg CaCO ₃ /L	No Guideline	5	8	No Guideline	ND	9	No Guideline	ND	No Guideline
Alkalinity (Total)	mg CaCO ₃ /L	No Guideline	5	8	No Guideline	190	9	No Guideline	160	No Guideline
Aluminium (Soluble)	mg/L	0.2	0.05	8	8	ND	9	9	ND	100%
Aluminium (Total)	mg/L	0.2	0.05	8	8	ND	9	9	ND	100%
Ammonia-N	mg/L	0.5	0.02	NR			9	9	0.02	100%
Calcium	mg/L	200	0.5	8	8	26	9	9	22	100%
Calcium (Filtered)	mg/L	200	0.5	NR			9	9	22	100%
Chloride	mg/L	250	5	8	8	140	9	9	100	100%
Colour True	PCU	15	5	27	27	8.3	27	27	ND	100%
Electrical Conductivity	uS/cm	No Guideline	10	27	No Guideline	860	27	No Guideline	640	No Guideline
Filterable Reactive Phosphorus	mg/L	No Guideline	0.01	8	No Guideline	0.01	9	No Guideline	0.06	No Guideline
Hardness	mg CaCO ₃ /L	200	5	8	8	120	9	9	100	100%
Iron (Soluble)	mg/L	0.3	0.01	27	8	7	27	27	0.05	100%

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Iron (Total)	mg/L	0.3	0.01	27	6	8.5	27	26	0.36	96.2%
Magnesium (Filtered)	mg/L	No Guideline	0.5	NR			9	No Guideline	14	No Guideline
Magnesium (Total)	mg/L	No Guideline	0.5	8	No Guideline	15	9	No Guideline	14	No Guideline
pH	pH	6.5-8.5		24	24	7.9	117	117	8.5	100%
Reactive Silica	mg/L	80	0.1	8	8	18	9	9	18	100%
Sodium	mg/L	180	0.5	8	8	110	9	9	61	100%
Sulfate	mg/L	250	1	8	8	19	9	9	14	100%
Total Dissolved Solids	mg/L	600	5	27	26	620	27	27	470	100%
Turbidity	NTU	5		24	24	3.68	117	117	0.32	100%
Zinc	mg/L	3	0.005	NR			9	9	0.022	100%

- Note 1:** Raw water is blended and treated prior to supply to consumers. Raw water is not provided to consumers and raw water data presented in this report is for operational purposes.
- Note 2:** pH and Turbidity are Busselton Water in-house tests. All others are NATA accredited test results.
- Note 3:** Total Dissolved Solids results vary from bore to bore and are being carefully monitored for the impacts of borefield saline intrusion.
- Note 4:** One Iron (Total) result outside the Australian Drinking Water aesthetic guideline of 0.3 mg/L was recorded in the distribution network during the reporting period. The sample (0.36 mg/L) was taken at Kathleen Crescent on 13 August 2025. No adverse customer or operational impacts resulted.

ADWG	Australian Drinking Water Guidelines
Bq/L	Becquerels per litre
CFU	Colony Forming Units
HU	Platinum-Cobalt Units
mg/L	milligrams per litre
NTU	Nephelometric Turbidity Units
pH	Acidity/basicity
uS/cm	Micro siemens per centimetre
mg CaCO ₃ /L	milligrams per litre as calcium carbonate
ND	Not Detected
NR	Not Required
No Guideline	No ADWG guideline. Compliance is not required or shown for these analytes/

6.0 Perfluoroalkyl and Polyfluoroalkyl Substances (PFAS) Performance

Perfluoroalkyl and Polyfluoroalkyl substances (PFAS) are a family of manufactured chemicals which do not occur naturally in the environment. PFAS has been identified in the environment at several known and suspected contaminated sites in Western Australia including one in Busselton. No PFAS was detected in Busselton Water's source water when the site was identified and liaison continues with the City of Busselton, the Department of Health and the Department of Water and Environmental Regulation regarding ongoing monitoring and testing.

Busselton Water commenced a PFAS/PFOS sampling regime of its raw water (bores) and throughout the distribution network in FY 2023-24. This sampling was initially undertaken on a quarterly basis in September and November 2023 and February, May and August 2024. PFAS was not detected in any of these samples and it was therefore determined that commencing in 2025, sampling would be carried out on a six-monthly basis in February and August 2025.

6.1 Perfluoroalkyl and Polyfluoroalkyl Substances (PFAS)

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Perfluoroalkyl sulfonamido substances - Trace										
Perfluorooctane sulfonamide (FOSA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
N-methylperfluoro-1-octane sulfonamide (N- MeFOSA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
N-ethylperfluoro-1-octane sulfonamide (N-EtFOSA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
2-(N-methylperfluoro-1-octane sulfonamido)-ethanol(N- MeFOSE) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
2-(N-ethylperfluoro-1-octane sulfonamido)-ethanol(N- EtFOSE) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
N-ethyl-perfluorooctanesulfonamidoacetic acid (N- EtFOSAA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
N-methyl-perfluorooctanesulfonamidoacetic acid (N- MeFOSAA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Perfluoroalkyl carboxylic acids (PFCAs) – Trace										
Perfluorobutanoic acid (PFBA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluoropentanoic acid (PFPeA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorohexanoic acid (PFHxA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluoroheptanoic acid (PFHpA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorooctanoic acid (PFOA) ^{N11}	ug/L	0.56	0.001	7	7	ND	13	13	ND	100%
Perfluorononanoic acid (PFNA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorodecanoic acid (PFDA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorotridecanoic acid (PFTrDA) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluoroundecanoic acid (PFUnDA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorododecanoic acid (PFDoDA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorotetradecanoic acid (PFTeDA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
n:2 Fluorotelomer sulfonic acids (n:2 FTSA)- Trace										
1H,1H,2H,2H-perfluorohexanesulfonic acid (4:2 FTSA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
1H,1H,2H,2H-perfluorooctanesulfonic acid(6:2 FTSA) ^{N11}	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
1H,1H,2H,2H-perfluorodecanesulfonic acid (8:2 FTSA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
1H,1H,2H,2H-perfluorododecanesulfonic acid (10:2 FTSA) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline

Type	Unit	ADWG Guideline	Lab Limit of Reporting	Raw Water (Bores)			Distribution Water			
				Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Number Assessed	Number Complying with ADWG Guideline	Maximum Individual Value	Compliance (%)
Perfluoroalkyl sulfonic acids (PFASs)- Trace										
Perfluorobutanesulfonic acid (PFBS) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorononanesulfonic acid (PFNS) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluoropropanesulfonic acid (PFPrS) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluoropentanesulfonic acid (PFPeS) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorohexanesulfonic acid (PFHxS) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	0.002	No Guideline
Perfluoroheptanesulfonic acid (PFHpS) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Perfluorooctanesulfonic acid (PFOS) ^{N11}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	0.012	No Guideline
Perfluorodecanesulfonic acid (PFDS) ^{N15}	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
PFASs Summations										
Sum (PFHxS + PFOS)*	ug/L	0.07	0.001	7	7	ND	13	13	0.014	100%
Sum of enHealth PFAS (PFHxS + PFOS + PFOA)*	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Sum of PFASs (n=30)*	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Sum of US EPA PFAS (PFOS + PFOA)*	ug/L	No Guideline	0.001	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Sum of WA DWER PFAS (n=11)*	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline
Sum of WA DWER PFAS (n=11)*	ug/L	No Guideline	0.005	7	No Guideline	ND	13	No Guideline	ND	No Guideline

7.0 Radiological Performance

7.1 Radiological – Exception Notifications

Radiological Water Quality Exceptions							
Locality	Population served	Date	Radiological Characteristic	MoU Alert Level	Remedial Action	DoH Notified	Close Out Date
Busselton	>30,000	01/07/2025 to 30/09/2025			NIL		

7.2 Radiological Performance

Radiological performance is sampled every two years, in April. It was undertaken in April 2024 and results were detailed in the Water Quality Report for the April to June 2024 reporting period. Radiological sampling will next be conducted in April 2026.

8.0 Planned Sample Summary (Quarter Ending 30 September 2025)

Locality	Microbiological			Physical and Chemical			Radiological			Fluoride		
	Planned	Taken	% Taken	Planned	Taken	% Taken	Planned	Taken	% Taken	Planned	Taken	% Taken
Busselton	183	183	100%	1811	1811	100%	N/A	N/A	N/A	54	54	100%

Note 1: Chemical testing totals shown in Table 8.0 relate to scheduled NATA and in-house sampling undertaken in accordance with Busselton Water's Water Quality Monitoring Program, which has been endorsed by the Department of Health.

8.1 Planned Sample Exceptions

Planned Sample Exceptions			
Locality	Characteristic (Microbiological/ Physical and Chemical/ Radiological)	Number of Samples	Reason for missed sample
Busselton	Physical and Chemical – Aesthetic		Nil

9.0 General Notes / Other News

Nil